

GOVERNMENT OF MAHARASHTRA**Dr. Babasaheb Ambedkar Research and Training Institute, Pune**

(An Autonomous Institute of Social Justice And Special Assistance Department, Govt. of Maharashtra)

**COMMON SET OF CLARIFICATIONS
FOR**

E-TENDER NOTICE No: - BARTI/PUNE/ADVT.TUB/PRO/32/1873/2013-14

AND

CORRIGENDUM TO TENDER NOTICE

E-TENDER NOTICE No: - BARTI/PUNE/ADVT.TUB/PRO/32/1873/2013-14

Name of Work : Supply, Installation, Testing, Commissioning & Maintaining roof top grid interactive PV solar power plant using multi-crystalline PV modules at following locations and Supply, Installation, Testing and Commissioning of LED light fittings at various campus locations.

- a) At Yerwada premises, Pune – 40 Kw
- b) At Queen's Garden premises, Pune – 40 Kw
- c) At Mahad premises – 100 Kw
- d) LED light fittings at various locations

To

All the Bidders,

Please find Common Set of Clarifications (CSC) in response to queries raised by the bidders along with this communications.

Please note that schedule of Bid Submission is as below:

S. No.	Action by BARTI	Action by Bidders	From	Up to
1	Publication of tender notice	NA	18/07/2013 from 10.00 hrs	18/07/2013 up to 18.30 hrs
2	NA	Bid Document downloading and purchase	18/07/2013 from 18.31 hrs	08/08/2013 up to 15.00 hrs
3	Closure of sale of bid document	NA	08/08/2013 from 15.01 hrs	08/08/2013 up to 17.30 hrs
4	NA	Submission of technical and financial bid (re-inscription of original bid document)	08/08/2013 from 17.31 hrs	12/08/2013 up to 15.00 hrs

5	Opening of technical bid (if possible)	NA	13/08/2013 from 15.01 hrs	13/08/2013 up to 17.00 hrs
6	Opening of financial bid (if possible)	NA	13/08/2013 from 17.01 hrs	16/08/2013 up to 16.00 hrs
7	Acceptance of payment against cost of bid document and EMD	Submission of bid security (EMD) & cost of bid document	18/07/2013 from 17.31 hrs	13/08/2013 up to 14.00 hrs

This communication is a part and parcel of the bid document.

Sd/-
Director General
Dr. Babasaheb Ambedkar Research and Training Institute
Pune

Total pages – 4 nos.

GOVERNMENT OF MAHARASHTRA**Dr. Babasaheb Ambedkar Research and Training Institute, Pune**

(An Autonomous Institute of Social Justice And Special Assistance Department, Govt. of Maharashtra)

**COMMON SET OF CLARIFICATIONS
FOR**

E-TENDER NOTICE No: - BARTI/PUNE/ADVT.TUB/PRO/32/1873/2013-14

AND

CORRIGENDUM TO TENDER NOTICE

E-TENDER NOTICE No: - BARTI/PUNE/ADVT.TUB/PRO/32/1873/2013-14

Name of Work : Supply, Installation, Testing, Commissioning & Maintaining roof top grid interactive PV solar power plant using multi-crystalline PV modules at following locations and Supply, Installation, Testing and Commissioning of LED light fittings at various campus locations.

- e) At Yerwada premises, Pune – 40 Kw
- f) At Queen's Garden premises, Pune – 40 Kw
- g) At Mahad premises – 100 Kw
- h) LED light fittings at various locations

Sr. No.	Points raised by Bidder	Clarifications declared by Employer
1	What equipment will be powered using solar? Rating in Kw per equipment is better to have so that we can engineer requirement system capacity accordingly.	Office load comprising of lighting, A.C. & office equipments. Individual load details cannot be given.
2	Space for Panels available is 15000 or 6000 sq ft at respective sites?	Space is not a problem at all sites.
3	For inverter, battery bank we need 30 sq. ft. of area (per 1kw + 4 hour battery backup).	Inverter shall be mounted outside. This is a on grid system, so no need of battery space.
4	Customer has asked for LED lighting, however BOQ for the same is unavailable. We need to have BOQ for the same along with specifications for all types considered by customer.	LED fixture BOQ is up-loaded on site.

5	Are LED fixtures also considered in total equipment load to be connected to Solar Power Plant?	LED light fixture load is considered in total load of individual site.
6	Requirement of Project Manager is assumed for the duration of 2 months. Please guide on this.	Project manager will be required till proper handing over.
7	There is requirement of Site Engineer. From RFP, we understand that the person would have to be considered for duration of 5 years on site deployment. His responsibility would be to maintain Solar Power Plant in healthy state and take care of periodic checks, power generation reporting and fault fix. Kindly confirm.	No need to deploy a person for operation. He should visit site periodically.
8	There are only few companies in market who can provide equipment of same specifications, model and make as there is a less tie ups of particular manufacturing company.	The bidders must upload An undertaking stating that the bidder is offering his quote is based only on approved makes of products stated in the bid document as a part of Technical Bid.
9	We feel that we can match with some of the specifications but with different models of different makes and manufacturing company etc. can we supply the same.	The bidders must upload An undertaking stating that the bidder is offering his quote is based only on approved makes of products stated in the bid document as a part of Technical Bid.

Sd/-
Director General
Dr. Babasaheb Ambedkar Research and Training Institute
Pune